

CERTIFICATE

No. Z1A 04 03 16006 019



Holder of Certificate: CAREL S.p.A.

Via dell'Industria, 11
35020 Brugine (PD)
Italy

Certification Mark:



Product: Air conditioning equipment

The product was tested on a voluntary basis and complies with the essential requirements. It meets the requirements of May 11, 2001 of the German Equipment Safety Law. The certification marks shown above can be affixed on the product. See also notes overleaf.

Test report no.: SIC03175.01

Date, 2004-03-10



Page 1 of 2

CERTIFICATE

No. Z1A 04 03 16006 019



Model(s):

UEXXYDZZZ, UEXXYKZZZ, UEXXYLZZZ
UE001HD000, UE001PD000, UE003HD000,
UE003HK000, UE003HL000, UE003PD000,
UE003PK000, UE003PL000, UE005HD000,
UE005HK000, UE005HL000, UE005PD000,
UE005PK000, UE005PL000, UE008HK000,
UE008HL000, UE008PK000, UE008PL000,
UE010HK000, UE010HL000, UE010PK000,
UE010PL000, UE015HK000, UE015HL000,
UE015PK000, UE015PL000, UE025HK000,
UE025HL000, UE025PK000, UE025PL000,
UE035HK000, UE035HL000, UE035PK000,
UE035PL000, UE045HL000, UE045PL000,
UE065HL000, UE065PL000, UE090HL000,
UE130HL000.

Parameters:

Rated voltage:
230V (1ph), 230V (3ph), 400V (3ph)
Rated frequency: 50/60 Hz
Rated power: from 1.12 to 97.50 kW
Protection class: I
Degree of protection against liquid:
IP20
Vapour capacity: from 1.5 to 130 Kg/h

XXX = instant rated steam production: 001 to 130
Y = type of control: P, H
ZZZ = client personalization
(not involving safety)
D, K, L = 230V 1ph version (D),
230V 3ph version (K), 400V 3ph version (L)

Tested according to:

EN 60335-2-88:2002

Production Facility(ies):

16006

